

DECLARATION OF PERFORMANCE | No.001

BS EN 1366-5 FIRE RESISTING SERVICE ENCLOSURE

Unique identification code of the product-type: Harcom[®] Fire Resisting Service Enclosure

Intended use/es: EN 1366-5 Fire Resisting Service Enclosure for 120 minutes Integrity and Insulation.

System/s of AVCP: 1

Harmonised standard: BS EN12101-3

Notified body/ies: Efectis France

Declared performance/s:

Essential Characteristics	Performance	Harmonised Technical Specification
Integrity Insulation Mechanical Stability	EI120 (Ve Ho o>i) EI120 (Ve Ho i>o)	BS EN13501-2:2023

The performance of the product identified above is in conformity with the set of declared of performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of:



Name: Steve Harrison

Title: Managing Director

Signature: 

At/On: Central House, 25 Camperdown Street, London E1 8DZ
28/04/2026